

This test for microbiological contamination was conducted on a fuel sample using the FUELSTAT® Plus test kit in accordance with ASTM D8070 and the results reported below were read using the FUELSTAT® Result app.

REGISTERED USER

Registered User: Sian Hodson-Kilroy
 Company name: Conidia
 Customer reference:

Address:
 Post code:
 Country:

TEST DATA

Tester name:
 Location/Site: ABC
 Asset Identity:
 Tank Reference:
 GPS location: 51°25'7.2"N
 0°34'8.2"W
 FUELSTAT Test Lot #:

FUELSTAT result #: 11,447
 Type of Test:
 Test date: 09-SEP-2019
 Printout date: 07-JAN-2022
 Phone make: Apple
 Phone model: iPhone 7
 App version:
 Portal version: 1.5.4

TEST RESULT CONTAMINATION ALERT LEVELS

Bacteria: **NEGLIGIBLE**
 Fungi: **HEAVY**
 Hormoconis resinae: **NEGLIGIBLE**
OVERALL RESULT: HEAVY

NOTES

DISCLAIMER

FUELSTAT® Result is designed for use with tests which are fully compliant with ASTM D8070. However, readings obtained using FUELSTAT® Result are currently outside the scope of ASTM D8070. Operators should visually validate test results as per ASTM D8070. The accuracy of this report may be dependent on the accuracy of the sample provided.

Full terms of use available on the website: www.conidia.com
 For any technical assistance telephone: **+44 (0)1491 829102**

RESULT LIMIT INDUSTRY GUIDELINES

Phase	Target antigen limits	Alert level
Fuel	Up to 150 µg/L	NEGLIGIBLE
Water	Up to 33 µg/ml	
Fuel	Between 150-750 µg/L	MODERATE
Water	Between 33-166 µg/ml	
Fuel	Greater than 750 µg/L	HEAVY
Water	Greater than 166 µg/ml	